

HOT AND COLD WATER SYSTEMS

WHEN TO SAMPLE FOR LEGIONELLA?

When Risk Assessment considers it as necessary




In high-risk areas or where there is a population with increased susceptibility



When water is stored (stagnant), or water distribution temperatures are between 25-45°C



After a suspected outbreak or illness



When the control levels of the treatment regime, e.g. temperature or disinfectant concentrations are not being consistently achieved

To find out more about how we can support your business to take a bespoke, strategic approach to water usage, contact us.

Visit totalwatersolutions.co.uk Call 0800 028 3557 or email tw@nwl.co.uk